



Food Grease Storage Tank Monthly Inspection Checklist

EOSMS-404-4

Last Updated: 01/13/2014

Page 1 of 1

Date: _____ Time: _____ Inspector: _____ Inspector's signature: _____	Status Indicator ✓ = Satisfactory, no action required NA = Not applicable R = Repair or action required C = Additional comments attached on separate sheet
--	---

Inspection Items	Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec
There is no significant cracking or spilling of secondary containment walls or floors												
External tank or container surfaces are not in contact with water												
Tank or container supports are in satisfactory condition												
There is no evidence of tank or container settlement or foundation deterioration												
Grounding straps are secured and in good condition												
Tank or container coatings are in good condition												
There are no visible signs of stress, leakage, corrosion, rusted support connections, or other potentially significant degradation.												
Interstitial space of double wall tank is free of liquid												
There is no noticeable tank shell/head distortions, buckling, denting or bulging												
There is no evidence of tank shell/head corrosion or cracking												
No evidence of spills or releases (pooling, staining, etc.)												
Emergency, bypass, or other unused drain valves are locked												
Drainage pipes and valves are fit for continued service												
Unloading procedures are in place and have been communicated to appropriate personnel and haulers												
All necessary spill control equipment is present												
Spill control materials are in good condition and have not passed expiration date(s)												
Lighting is sufficient for nighttime spill release detection												
Egress pathways are clear												